

IBA-1, I-BEAM ADAPTER MOUNTING INSTRUCTIONS

IBA-1 Mounted on I-Beam or U-Channel

Positioning IBA-1 on I-Beam

NFPA-10 requires the Bottom of the fire extinguisher must be at least 6 inches above the floor.

The Top of fire extinguisher must be NO higher than 60 inches above the floor.



Select approximate mounting position on beam or channel iron.

Do NOT tighten square-headed bolt yet.

Determine if extinguisher will be mounted on side of beam or face of beam.

Extinguisher mounted on Face of Beam



Mount Fire Extinguisher bracket on IBA-1 and tighten securely.

Extinguisher mounted on Side of Beam



Mount IBA-1 on I-Beam or channel iron and tighten square-headed bolt.

IBA-1 Mounted on Pallet Rack

Select mounting position on rack.
Do NOT tighten square-headed bolt yet.



Determine if extinguisher will be mounted on side of rack as shown or front of rack (on top of "*1/4 China*" text).

Mount Fire Extinguisher bracket on IBA-1 and tighten securely.

Tighten square-headed bolt to secure IBA-1 on rack.

Bracket shown below mounted on end of rack with fender washer and 1/4"-20 nut on inside of Rack channel (IBA-1 not needed).

